

PRODUCT CERTIFICATION SCHEME SDP11-02

Certificate number: IFCC1255

This is a product certificate to certify that

Coopers Fire Ltd.

Edward House, Penner Road, Havant,
Hampshire, PO9 1QZ, United Kingdom

Who fabricate the following product:

Product:	FireMaster® Plus ² - Active Fire Curtain Barrier Assembly as an 'single' construction using EFP™ 2/1000/DGI fabric
Product Standard:	BS 8524-1:2013
Fire Resistance:	180 minutes integrity and 90 minutes Radiation performance to BS EN 1634-1:2014 (BS EN 1363-1:2012 & BS EN 1363-2:1999)
Classification:	E15, E20, E30, E45, E60, E90, E120 and E180, plus EW20, EW30, EW60 and EW90 to BS EN 13501-2:2007+A1:2009
Smoke Leakage:	3m ³ /m/h to BS EN 1634-3:2004

*have satisfied the requirements of scheme SDP11-2 this includes evaluation of the product performance in accordance with **BS 8524-1:2013**, inspection of the Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application are detailed in the Schedule referenced below.*



Schedule ref: IFCC1255/S01
First Issued: 19th July 2016
Revised: 01 Aug 2018
Valid to: 18th July 2021
Issue No: 3



175

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire, HP27 9AH, UK,
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.