
CERTIFICATE OF APPROVAL

No CF 5624

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

COOPERS FIRE LTD

Edward House, Penner Road, Havant, Hants, PO9 1QZ
Tel: 02392 454405

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT

FireMaster® A1 Active
Fire Curtain

TECHNICAL SCHEDULE

TS 42 – Fire Resisting
Pedestrian Doorsets and
Openable Windows with Fire
Resisting and/or Smoke
Control Characteristics

Signed and sealed for and on behalf of Exova (UK) Limited trading as
Warrington Certification



Paul Duggan
Certification Manager



Issued: 24th May 2018
Next audit test due: 24/05/2019
Frequency: Annually
Valid to: 23rd May 2023

Page 1 of 2



CERTIFICATE No CF 5624

COOPERS FIRE LTD

FireMaster® A1 Active Fire Curtain

1. This approval relates to the use of FireMaster® A1 Active Fire Curtains in providing the following classifications against the requirements of EN 13501-2: 2007 + A1: 2009.

Overlapped fire curtain (WF Classification Report No.351655):

Fire resistance classification: E120-C0 and EW60-C0

Single-span fire curtain (WF Classification Report No. 343633):

Fire resistance classification: E180-C0 and EW30-C0

2. The product is CERTIFIRE approved on the basis of:
 - i) Initial type testing and classification against EN 13501-2: 2007 + A1: 2009.
 - ii) An appraisal against TS30.
 - iii) Inspection and surveillance of factory production control
3. The approval relates to on-going production. Product and/or its immediate packaging is identified with the manufacturers' name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.
4. The field of application for the FireMaster® A1 Active Fire Curtains shall be identical to that classified within WF Classification Report Nos. 351655 and 343633 (i.e. specification, dimensions, fire exposure direction, etc.). No extension or change of scope beyond that tested and classified is provided.
5. The scope of approval relates to classification against the requirements of EN 13501-2: 2007 + A1: 2009 only. This document does not confer compliance against the requirements of any relevant product standard for the purposes of CE Marking.