
CERTIFICATE OF APPROVAL

No CF 5513

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

COOPERS FIRE LTD

Edward House, Penner Road, Havant, PO9 1QZ
Tel: 02392 454405

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:


CERTIFIED PRODUCT

FireMaster® Plus² Active Fire
Curtain

TECHNICAL SCHEDULE

TS 30 – Industrial Type Fire
Resisting Doorsets

Signed and sealed for and on behalf of Exova (UK) Limited trading as
Warrington Certification



Sir Ken Knight
Chairman
Impartiality Committee



Paul Duggan
Certification Manager



Issued: 20th March 2017
Valid to: 19th March 2022



CERTIFICATE No CF 5513

COOPERS FIRE LTD

FireMaster® Plus² Active Fire Curtain

1. This approval relates to the use of FireMaster® Plus² Active Fire Curtains in providing a fire resistance performance of up to 180 minutes integrity performance, as defined in BS EN 1634-1: 2008 The scope of approval is summarised as follows:

Continuous Barriers / Single Roller

Integrity Performance (mins)	Maximum Height (metres)	Maximum Width (metres)
120	5	7
180	4	7

All dimensions quoted in the above tables are internally between guides and from underside of head box to floor level (i.e. visible fabric dimensions)

2. The product is CERTIFIRE approved on the basis of:
- i) Initial type testing.
 - ii) An appraisal against TS30.
 - iii) Inspection and surveillance of factory production control
3. The approval relates to on-going production. Product and/or its immediate packaging is identified with the manufacturers' name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.
4. The FireMaster® Plus² Active Fire Curtains are approved for installation into concrete, masonry or timber stud partitions having a fire performance no less than that required for the fire curtain. Typical installation details are provided in the datasheet.