
CERTIFICATE OF APPROVAL

No CF 5625

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

COOPERS FIRE LTD

Edward House, Penner Road, Havant, Hants, PO9 1QZ
Tel: 02392 454405

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT

FireMaster® Plus² Active
Fire Curtain

TECHNICAL SCHEDULE

TS 42 – Fire Resisting
Pedestrian Doorsets and
Openable Windows with Fire
Resisting and/or Smoke
Control Characteristics

Signed and sealed for and on behalf of Exova (UK) Limited trading as
Warrington Certification



Paul Duggan
Certification Manager



Issued: 24th May 2018
Revised: 19th October 2018
Valid to: 23rd May 2023

Page 1 of 2



CERTIFICATE No CF 5625

COOPERS FIRE LTD

FireMaster® Plus² Active Fire Curtain

1. This approval relates to the use of FireMaster® Plus² Active Fire Curtains (single span only) in providing the following classifications against the requirements of EN 13501-2: 2016.

Single-span fire curtain (WF Classification Report No. 343634):

**Fire resistance classification: E180-C0 and
EW90-C0**

2. The product is CERTIFIRE approved on the basis of:
 - i) Initial type testing and classification against EN 13501-2: 2016.
 - ii) An appraisal against TS42.
 - iii) Inspection and surveillance of factory production control.
3. The approval relates to on-going production. Product and/or its immediate packaging is identified with the manufacturers' name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.
4. The field of application for the FireMaster® Plus² Active Fire Curtains shall be identical to that classified within WF Classification Report No. 343634 (i.e. specification, dimensions, fire exposure direction, etc.). No extension or change of scope beyond that tested and classified is provided.
5. The scope of approval relates to classification against the requirements of EN 13501-2: 2016 only. This document does not confer compliance against the requirements of any relevant product standard for the purposes of CE Marking.
6. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.