



Declaration of Performance

FIREMASTER® (SINGLE) FIRE CURTAIN BARRIER(S)

Manufacturer	COOPERS FIRE LIMITED, Edward House, Penner Road, Havant, Hampshire, PO9 1QZ, United Kingdom
Product:	FireMaster® A1 Active Fire Curtain Barrier Assembly as a 'single' construction using EFP™ A1 fabric
Product Standard:	BS 8524-1:2013
Fire Resistance:	180 minutes Integrity and 30 minutes Radiation performance to BS EN 1634-1:2014 (BS EN 1363-1:2016 & BS EN 1363-2:1999)
Classification:	E180 EW30 to BS EN 13501-2:2007+A1:2009
Smoke Leakage:	3m ³ /m/h to BS EN 1634-3:2004
IFC Certification Number	IFCC1160
Certification Notified Body	IFC CERTIFICATION LTD, 20 Park Street, Princes Risborough, Buckinghamshire, HP27 9AH, United Kingdom

Date of Issue: 1st September 2015
Valid until: 31st August 2020

David Cerquella

Managing Director
Date: 15th February 2019

COOPERS FIRE LTD
EDWARD HOUSE, PENNER ROAD,
HAVANT, HAMPSHIRE, UK. PO9 1QZ
T: +44 (0)2392 454 405
WWW.COOPERSFIRE.COM

COMPANY REGISTRATION
REGISTERED IN ENGLAND NUMBER: 2010274
REGISTERED OFFICE:
EDWARD HOUSE, PENNER ROAD,
HAVANT, HAMPSHIRE, UK. PO9 1QZ

