



Declaration of Performance

Vii® FIRE FIRE CURTAIN BARRIER(S)

Manufacturer	COOPERS FIRE LIMITED, Edward House, Penner Road, Havant, Hampshire, PO9 1QZ, United Kingdom
Product:	Vii®Fire A1 - Active Fire Curtain Barrier Assembly as a 'single' construction using EFP™ A1 fabric
Product Standard:	BS 8524-1:2013
Fire Resistance:	120 minutes Integrity and 30 minutes Radiation performance to BS EN 1634-1:2014 (BS EN 1363-1:2016 & BS EN 1363-2:1999)
Classification:	E15, E20, E30, E45, E60, E90, E120 EW20 & EW30 to BS EN 13501-2:2016
Smoke Leakage:	3m³/m/h to BS EN 1634-3:2004
IFC Certification Number	IFCC/1280
Certification Notified Body	IFC CERTIFICATION LTD, 20 Park Street, Princes Risborough, Buckinghamshire, HP27 9AH, United Kingdom

Date of Issue: 25th January 2017
Valid until: 24th January 2022

David Cerquella

Managing Director
Date: 15th February 2019

COOPERS FIRE LTD
EDWARD HOUSE, PENNER ROAD,
HAVANT, HAMPSHIRE, UK. PO9 1QZ
T: +44 (0)2392 454 405
WWW.COOPERSFIRE.COM

COMPANY REGISTRATION
REGISTERED IN ENGLAND NUMBER: 2010274
REGISTERED OFFICE:
EDWARD HOUSE, PENNER ROAD,
HAVANT, HAMPSHIRE, UK. PO9 1QZ

