



CERTIFICATE OF APPROVAL

No CF 5769

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

COOPERS FIRE LIMITED

Ignis House, Houghton Avenue, Waterlooville, Hampshire,
PO7 3DU, United Kingdom
Phone 02392 454405

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT

SmokeStop® Active Smoke
Barrier Overlapping Or Single
Barrel System (A2 Fabric)

TECHNICAL SCHEDULE

TS 30 – Industrial Type Fire
Resisting Doorsets

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan
Certification Manager

Issued:
Revised:
Valid to:

29th October 2019
18th May 2023
28th October 2024





CERTIFICATE No CF 5769

COOPERS FIRE LTD

1. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
2. This approval relates to the performance of active smoke barriers, manufactured by Coopers Fire Ltd. The barriers are certificated against the following performance requirements of EN 12101-1: 2005+ A1: 2006, at an unlimited width (subject to constructional requirements) (incorporating the use of barrel support brackets as defined in the Constructional Specification) at a maximum overall height (inc. headbox) of 4840mm:

Annex D - Temperature time (DA150 Classification).
Annex C - Smoke permeability (leakage rate not exceeding 25 m³ per hour per m²).
Annex B - Reliability/Response/Durability (pass).
3. The aforementioned barriers are also separately certificated against the essential requirements of Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR) under Certificate of Constancy of Performance referenced 2812-CPR-FA5012.
4. The product is CERTIFIRE approved on the basis of:
 - i) Initial type testing.
 - ii) An appraisal against TS30.
 - iii) Inspection and surveillance of factory production control
 - iv) Audit testing (as defined in TS30)
5. The approval relates to on-going production. Product and/or its immediate packaging is identified with the manufacturers' name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.

Signed
E/355

Page 2 of 2

Issued: 29th October 2019
Revised: 18th May 2023
Valid to: 28th October 2024