



CERTIFICATE OF APPROVAL

No CF 5860

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

Coopers Fire Ltd

Edward House, Penner Road, Havant, Hants,
PO9 1QZ
TEL: 02392 454405

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT

FireMaster Cleanroom Active Fire
Curtain

TECHNICAL SCHEDULE

TS 30 – Industrial Type Fire
Resisting Doorsets

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan
Certification Manager

Issued:
Valid to:

30th April 2020
29th April 2025





CERTIFICATE No CF 5860

Coopers Fire Ltd

1. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
2. This approval relates to the use of FireMaster Cleanroom Active Fire Curtains in providing a fire resistance performance of up to 120 minutes integrity performance, as defined in BS EN 1634-1: 2014. The scope of approval is summarised as follows:

Continuous Barrier / Single Roller

Integrity (mins)	Maximum height (metres)	Maximum Width (metres)
90	4	4
120	3	4

All dimensions quoted in the above tables are internally between guides and from underside of head box to floor level (i.e. visible fabric dimensions).
For all Fire Curtains over 2500mm wide a mid-span barrel support bracket is required.

3. The product is CERTIFIRE approved on the basis of:
 - i) Initial type testing
 - ii) An appraisal against TS30
 - iii) Inspection and surveillance of factory production control
4. The approval relates to ongoing production. Product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.
5. The FireMaster Cleanroom Active Fire Curtains are approved for installation into concrete, masonry or timber stud partitions having a fire performance no less than that required for the fire curtain. Typical installation details are provided in the datasheet.

Signed
E/189

Issued: 30th April 2020
Valid to: 29th April 2025