



CERTIFICATE OF APPROVAL

No CF 5795

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

Coopers Fire Ltd

**Ignis House, Houghton Avenue, Waterlooville, Hampshire,
PO7 3DU
TEL: 02392 454405**

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT

**FireMaster Horizontal Active Fire
Curtain**

TECHNICAL SCHEDULE

**TS 30 – Industrial Type Fire
Resisting Doorsets**

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

**Paul Duggan
Certification Manager**



Issued: 13th November 2019
Revised: 14th August 2020
Valid to: 12th November 2024





FireMaster Horizontal Active Fire Curtain

1. This approval relates to the use of the Firemaster Horizontal Active Fire Curtain in providing a fire resistance performance of up to 120 minutes integrity performance, were it subject to test using the general principles of BS EN 1634-1:2014 + A1:2018, for exposure from below. The scope of approval is summarised as follows:

Continuous Barrier / Single Roller

Integrity (mins)	Maximum Length (metres)	Maximum Width (metres)
120	7.0	7.0

All dimensions quoted in the above table are the outer dimensions of the entire construction (head boxes and side guides).

2. The product is CERTIFIRE approved on the basis of:
 - i) Initial type testing.
 - ii) An appraisal against TS30.
 - iii) Inspection and surveillance of factory production control
3. The approval relates to on-going production. Product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.
4. The FireMaster Horizontal Active Fire Curtains are approved for installation into apertures in concrete or masonry flooring having a fire performance no less than that required for the fire curtain. Typical installation details are provided in the datasheet.
5. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.

E/355

Page 2 of 2

Issued: 13th November 2019

Revised: 14th August 2020

Valid to: 12th November 2024