



CERTIFICATE OF CONSTANCY OF PERFORMANCE

1720-CPR-0038

In compliance with Statutory Instruments 2019 No.465 of the United Kingdom Houses of Parliament 5th March 2019 (The Construction Products (Amendment etc.) (EU Exit) Regulations 2019), this certificate applies to the construction product:

SmokeStop Evacu8 Smoke Barrier

a multi-strip smoke barrier

Particular conditions applicable: Units having an unlimited width and a maximum drop of 6700mm. Width of each strip is a minimum of 600mm with a minimum overlap of 30mm

placed on the market by

**Coopers Fire Ltd.
Ignis House, Houghton Avenue, Waterlooville,
Hampshire,
PO7 3DU
United Kingdom**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

BS EN 12101-01:2005 + A1:2006

Under system 1 are applied and that the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 1st January 2021 and will remain valid as long as neither the designated standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are not modified significantly unless suspended or withdrawn by the approved product certification body.



Princes Risborough, UK

A handwritten signature in black ink, appearing to read 'Ian Woodhouse', is written over a light blue horizontal line.

Director of Certification

IFC Certification Ltd
UK Approved Body No. 1720

20 Park Street, Princes Risborough, Buckinghamshire, HP27 9AH, UK
Tel: +44(0) 1844 275500, Fax: +44(0) 1844 274002, E-mail: info@ifccertification.com
Registered No: 4777898 England
©IFC Certification Ltd 2021