



PRODUCT CERTIFICATION SCHEME SDP11-02

Certificate number: IFCC 1256

This is a product certificate to certify that

Coopers Fire Ltd,.

Ignis House, Houghton Avenue
Waterlooville, Hampshire
PO7 3DU, United Kingdom

Who fabricate the following product:

Product:	FireMaster® A1 Concertina™ A1 - Active Fire Curtain Barrier Assembly as an 'closed' construction using EFP™ A1 fabric
Product Standard:	BS 8524-1:2013
Fire Resistance:	240 minutes integrity and 30 minutes Radiation performance to BS EN 1634-1:2014 (BS EN 1363-1:2012 & BS EN 1363-2:1999)
Classification:	E15, E20, E30, E45, E60, E90, E120, E180 and E240, plus EW20 and EW30 to BS EN 13501-2:2007+A1:2009

*have satisfied the requirements of scheme SDP11-2 this includes evaluation of the product performance in accordance with **BS 8524-1:2013**, inspection of the Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application are detailed in the Report referenced below.*



Report ref: FSA 15782_01B
First Issued: 19 July 2016
Reissued: 06 October 2021
Valid to: 18 July 2026
Issue No: 3



175

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire, HP27 9AH, UK,
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.