



---

## CERTIFICATE OF APPROVAL

### No CF 5624

---

This is to certify that, in accordance with  
TS00 General Requirements for Certification of Fire Protection Products  
The undermentioned products of

## COOPERS FIRE LTD

Ignis House, Houghton Avenue, Waterlooville,  
Hants, PO7 3DU  
Tel: 02392 454405

Have been assessed against the requirements of the Technical Schedule(s)  
denoted below and are approved for use subject to the conditions  
appended hereto:

---

#### CERTIFIED PRODUCT

FireMaster® A1 Active  
Fire Curtain

#### TECHNICAL SCHEDULE

TS 42 – Fire Resisting  
Pedestrian Doorsets and  
Openable Windows with Fire  
Resisting and/or Smoke  
Control Characteristics

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan  
Certification Manager



Issued: 24<sup>th</sup> May 2018  
Revised: 28<sup>th</sup> October 2020  
Valid to: 23<sup>rd</sup> May 2023





---

## CERTIFICATE No CF 5624

### COOPERS FIRE LTD

---

#### FireMaster® A1 Active Fire Curtain

1. This approval relates to the use of FireMaster® A1 Active Fire Curtains in providing the following classifications against the requirements of EN 13501-2: 2007 + A1: 2009 (single-span) and EN 13501-2:2016 (overlapped).

Overlapped fire curtain (WF Classification Report No.405186A):

**Fire resistance classification: E120-C0 and EW30-C0**

Single-span fire curtain (WF Classification Report No. 343633):

**Fire resistance classification: E180-C0 and EW30-C0**

2. The product is CERTIFIRE approved on the basis of:
  - i) Initial type testing and classification against EN 13501-2: 2007 + A1: 2009 / EN 13501-2: 2016.
  - ii) An appraisal against TS42.
  - iii) Inspection and surveillance of factory production control
3. The approval relates to on-going production. Product and/or its immediate packaging is identified with the manufacturers' name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.
4. The field of application for the FireMaster® A1 Active Fire Curtains shall be identical to that classified within WF Classification Report Nos. 405186A and 343633 (i.e. specification, dimensions, fire exposure direction, etc.). No extension or change of scope beyond that tested and classified is provided.
5. The scope of approval relates to classification against the requirements of EN 13501-2: 2007 + A1: 2009 (single-span) and EN 13501-2:2016 (overlapped) only. This document does not confer compliance against the requirements of any relevant product standard for the purposes of CE Marking.
6. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.