



coopers

SMOKE AND FIRE CURTAINS

EC Declaration of Conformity

In accordance with EN ISO 17050-1:2004

FIREMASTER® FIRE CURTAINS

This declaration of conformity is issued under the sole responsibility of the manufacturer.

Coopers Fire Ltd declare that: FireMaster® Fire Curtains
Are manufactured and delivered in accordance with the following directives:

Machinery Directive 2006/42/EC

Harmonised standards:

EN 60204-1	Safety of machinery - Electrical equipment of machines - Part 1 General requirements
EN 13849-1	Safety of machinery - Safety-related parts of control systems - Part 1 General principles for design
EN 13837	Safety of machinery - Safety distances to prevent hazard zones being reached by upper and lower limbs
EN 12453	Industrial, commercial and garage doors and gates. Safety in use of power operated doors. Requirements and test methods
EN 61310-1	Safety of machinery – Indication, marking and actuation – Part 1: Requirements for visual, acoustic and tactile signals
EN 13241	Industrial, commercial, garage doors and gates – Product standard, performance characteristics

EMC Directive 2004/108/EC

Harmonised standards:

EN 61000-3-2	Limits for harmonic current emissions
EN 61000-3-3	Assessment of emission limits for the connection of unbalanced installations to MV, HV and EHV power systems
EN 61000-4-2	Electrostatic discharge immunity test
EN 61000-4-3	Radiated, radiofrequency, electromagnetic field immunity test
EN 61000-4-4	Electrical fast transient/burst immunity test
EN 61000-4-5	Surge immunity test
EN 61000-4-6	Immunity to conducted disturbances, induced by radio-frequency fields
EN 61000-4-11	Voltage dips, short interruptions and voltage variations immunity tests for equipment with input current up to 16 A per phase
EN 61000-6-3	Emission standard for residential, commercial and light-industrial environments
EN 61000-6-4	Emission standard for industrial environments
EN 13241	Industrial, commercial, garage doors and gates – Product standard, performance characteristics

COOPERS FIRE LTD
IGNIS HOUSE, HOUGHTON AVENUE,
WATERLOOVILLE, HAMPSHIRE, UK. PO7 3DU
T: +44 (0)2392 454 405
WWW.COOPERSFIRE.COM

COMPANY REGISTRATION
REGISTERED IN ENGLAND NUMBER: 2010274
REGISTERED OFFICE:
IGNIS HOUSE, HOUGHTON AVENUE,
WATERLOOVILLE, HAMPSHIRE, UK. PO7 3DU





Low voltage directive 2006/95/EC

Harmonised standards:

EN 60204-1 Safety of machinery - Electrical equipment of machines - Part 1 General requirements

Construction Products Regulation 305/2011

Harmonised standards:

EN 16034 Pedestrian doorsets, industrial, commercial, garage doors and openable windows - Product standard, performance characteristics – Fire testing and/or smoke control characteristics

EN 13241 Industrial, commercial, garage doors and gates — Product standard, performance characteristics

David Cerquella

Managing Director

Date: 10th April 2024

COOPERS FIRE LTD
IGNIS HOUSE, HOUGHTON AVENUE,
WATERLOOVILLE, HAMPSHIRE, UK. PO7 3DU
T: +44 (0)2392 454 405
WWW.COOPERSFIRE.COM

COMPANY REGISTRATION
REGISTERED IN ENGLAND NUMBER: 2010274
REGISTERED OFFICE:
IGNIS HOUSE, HOUGHTON AVENUE,
WATERLOOVILLE, HAMPSHIRE, UK. PO7 3DU

