



## Declaration of Performance

### FIREMASTER® (SINGLE) FIRE CURTAIN BARRIER(S)

<b>Manufacturer:</b>	COOPERS FIRE LIMITED, Ignis House, Houghton Avenue, Waterlooville, Hampshire. PO7 3DU. United Kingdom
<b>Product:</b>	FireMaster® A1 Active Fire Curtain Barrier Assembly as a 'single' construction using EFP™ A1 fabric
<b>Fire Resistance:</b>	180 minutes Integrity and 30 minutes Radiation performance to BS EN 1634-1:2014 (BS EN 1363-1:2016 & BS EN 1363-2:1999)
<b>Classification:</b>	E180 EW30 to BS EN 13501-2:2007+A1:2009
<b>Smoke Leakage:</b>	3m <sup>3</sup> /m/h to BS EN 1634-3:2004
<b>IFC Certification Number:</b>	IFCC1160
<b>Product Standard:</b>	BS 8524-1:2013
<b>Certification Notified Body:</b>	IFC CERTIFICATION LTD, 20 Park Street, Princes Risborough, Buckinghamshire, HP27 9AH. United Kingdom
<b>Warrington Certification Number:</b>	CF 5459
<b>Test Standard:</b>	BS EN 1634-1:2014
<b>Certification Notified Body:</b>	WARRINGTONFIRE, Holmesfield Road, Warrington, Cheshire, WA1 2DS United Kingdom

**Date of Issue:** 1<sup>st</sup> September 2015  
**Valid until:** 31<sup>st</sup> August 2020

David Cerquella

Managing Director  
Date: 29<sup>th</sup> April 2020

Version 02-April20

COOPERS FIRE LTD  
IGNIS HOUSE, HOUGHTON AVENUE,  
WATERLOOVILLE, HAMPSHIRE, UK. PO7 3DU  
T: +44 (0)2392 454 405  
[WWW.COOPERSFIRE.COM](http://WWW.COOPERSFIRE.COM)

COMPANY REGISTRATION  
REGISTERED IN ENGLAND NUMBER: 2010274  
REGISTERED OFFICE:  
IGNIS HOUSE, HOUGHTON AVENUE,  
WATERLOOVILLE, HAMPSHIRE, UK. PO7 3DU

