



Declaration of Performance

FIREMASTER® CONCERTINA CLOSED FIRE CURTAIN BARRIER(S)

Manufacturer:	COOPERS FIRE LIMITED, Ignis House, Houghton Avenue, Waterlooville, Hampshire. PO7 3DU. United Kingdom
Product:	FireMaster® A1 Concertina™ A1 - Active Fire Curtain Barrier Assembly as an 'closed' construction using EFP™ A1 fabric
Product Standard:	BS 8524-1:2013
Fire Resistance:	240 minutes integrity and 30 minutes Radiation performance to BS EN 1634-1:2014 (BS EN 1363-1:2016 & BS EN 1363-2:1999)
Classification:	E240 EW30 to BS EN 13501-2:2007+A1:2009
IFC Certification Number	IFCC/1256
Certification Notified Body	IFC CERTIFICATION LTD, 20 Park Street, Princes Risborough, Buckinghamshire, HP27 9AH, United Kingdom

Date of Issue: 19th July 2016
Valid until: 10th January 2024

David Gerquella

Managing Director
Date: 11th January 2021

Version 03-Mar21

COOPERS FIRE LTD
IGNIS HOUSE, HOUGHTON AVENUE,
WATERLOOVILLE, HAMPSHIRE, UK. PO7 3DU
T: +44 (0)2392 454 405
WWW.COOPERSFIRE.COM

COMPANY REGISTRATION
REGISTERED IN ENGLAND NUMBER: 2010274
REGISTERED OFFICE:
IGNIS HOUSE, HOUGHTON AVENUE,
WATERLOOVILLE, HAMPSHIRE, UK. PO7 3DU

