

Declaration of Performance

DoP-CF-SBE-001

- 1. Unique classification code of the product type: Coopers SmokeStop® evacU8
- 2. Description of the product type: Coopers SmokeStop® evacU8 Smoke Barrier(s); Type ASB1/3
- 3. Intended use: Smoke barriers of smoke control in construction works in industrial and commercial locations
- 4. Contact address: COOPERS FIRE LIMITED

Ignis House, Houghton Avenue, Waterlooville, Hampshire. PO7 3DU. United Kingdom

- 5. System or systems of assessment and verification of constancy of performance of the construction product: System 1
- 6. Notified product certification body code No.1720 performed the determination of the product type, the initial inspection of the manufacturing plant and of FPC, the continuous surveillance, assessment and evaluation of the FPC and audit testing of samples taken before placing the product on the market and issued the certificate of constancy of performance.

7. Declared performance:

Essential characteristsics	Performance	Harmonized technical specification
Operational reliability	Pass	EN 12101-01:2005 + A1:2006 Clause 5.3
Response delay	Pass	EN 12101-01:2005 + A1:2006 Clause 5.4
Deployment safety	Pass	EN 12101-01:2005 + A1:2006 Clause 5.4
Fire Resistance - Smoke Leakage	Pass	EN 12101-01:2005 + A1:2006 Clause 5.5.5
Fire Resistance – Mechanical Stability	D ₆₀₀ A	EN 12101-01:2005 + A1:2006 Clause 5.2
Fire Resistance – Integrity	D ₆₀₀ A	EN 12101-01:2005 + A1:2006 Clause 5.2

8. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 7. The declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

Date: 29th April 2020

David Cerquella

Managing Director

Version 02-April20









