



Declaration of Performance

SMOKESTOP EVACU8 SMOKE BARRIER(S)

Unique identification code of the product-type:

SmokeStop EvacU8 Smoke Barrier(s);
type ASB1/3

Intended use:

Smoke control in construction works in
industrial and commercial locations

Name and address of the manufacturer:

Coopers Fire Limited
Ignis House, Houghton Avenue, Waterlooville,
Hants. PO7 3DU, UK

Notified body:

Name: CSI SPA
Number: 0497
Activity: Issuance of new certificate
Certificate: 0497-CPR-7128

Declared performance

Essential characteristics	Performance	Harmonised technical specification
Operational reliability	Pass	EN 12101-1: 2005+A1:2006, clause 5.3
Response delay	Pass	EN 12101-1: 2005+A1:2006, clause 5.4
Deployment safety	Pass	EN 12101-1: 2005+A1:2006, clause 5.4
Resistance to fire: <div>Smoke leakage Mechanical stability Integrity</div>	Pass Pass Pass	EN 12101-1: 2005+A1:2006, clause 5.2 – 5.5

David Cerquella

Managing Director
Date: 22nd July 2022

COOPERS FIRE LTD
IGNIS HOUSE, HOUGHTON AVENUE,
WATERLOOVILLE, HAMPSHIRE, UK. PO7 3DU
T: +44 (0)2392 454 405
WWW.COOPERSFIRE.COM

COMPANY REGISTRATION
REGISTERED IN ENGLAND NUMBER: 2010274
REGISTERED OFFICE:
IGNIS HOUSE, HOUGHTON AVENUE,
WATERLOOVILLE, HAMPSHIRE, UK. PO7 3DU



CF-DOP-EVAC
CFL-CF-065
v03 July 2022