



## CERTIFICATE OF CONSTANCY OF PERFORMANCE

1720-CPR-0117

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR)*, this certificate applies to the following construction products:

### Variospeed 6 [Type: ERU-1] Mk4 & Mk5 Controllers

Intended use – 230Vac 50Hz mains Power Supplies (as listed above) designed to control 24Vdc Motors [Type: Gravity Fail-Safe] for Active Smoke Barriers to BS EN 12101-1:2005+A1:2006 and Active Fire Curtain Barrier Assemblies to BS 8524-1:2013. Power Supplies complete with back-up batteries are fully protected in a suitably IP rated enclosure.

Produced by

**Coopers Fire Ltd**  
**Edward House, Penner Road, Havant, Hants PO9 1QZ**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

**EN 12101-10:2005**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

**constancy of performance of the construction product.**

This certificate was first issued on 23rd February 2016 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are not modified significantly unless suspended or withdrawn by the notified product certification body.



A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse  
Director of Certification

**IFC Certification Ltd**

**Notified Body No. 1720**

20 Park Street, Princes Risborough, Buckinghamshire, HP27 9AH, UK  
Tel: +44(0) 1844 275500, Fax: +44(0) 1844 274002, E-mail: info@ifccertification.com

Registered No: 4777898 England

©IFC Certification Ltd 2013