

COMPLIANCY AND FEATURES

 FireMaster® Concertina™ Egress active fire curtain barrier assemblies have been tested for fire resistance and self-closing to UL 10D and to the requirements of BS EN 1634-1:2014 for 'Fire Resistance'

- Motors and controls used with the FireMaster® Concertina™ Egress fire curtain barrier have been tested to UL 864 (10th Ed).
- Maximum width of 1000mm egress door
- The egress door can be installed on both the FireMaster Concertina Open and Closed products
- A ResQ-Window[™] Vision Panel can be installed into the curtain or egress door if required.
- Can be sign written to indicate point of egress



FIREMASTER CONCERTINA EGRESS IS THE FIRST MULTI-SIDE FIRE CURTAIN TO OFFER AN INTEGRAL EGRESS DOOR

TESTED TO

UL 10D (Fire Tests of Fire Protective Curtain Assemblies)

UL 864 (10th Ed) for Motors and Control BS EN 1634-1:2014 for 'Fire Resistance'

CERTIFICATION

Complete barrier assemblies are certified by UL and Warringtonfire



warringtonfire

R38679


PERIOD OF FIRE RESISTANCE

UL - 120 minutes endurance (for use in gypsum and masonry wall type constructions) with or without ResQ-Window™

BS EN 1634-1:2014 - 90 mins (Integrity E90) and 60 mins Radiation (Radiation Control EW60)

BENEFITS

- BARRIER EGRESS
 Egress of evacuees or access for emergency services through the barrier
- ANY POINT OF EGRESS
 Can include multiple egress doors at any exit point
- STANDARD CONFIGURATION
 Square, Rectangular, L Shaped and
 Circular FireMaster Open and Closed
 Concertina products available
- CUSTOMISED CONFIGURATION
 FireMaster Open and Closed designs can be configured to suit a variety of non-standard shapes and sizes
- NO COLUMNS AND CORNER POSTS REQUIRED
 No support posts required, the Concertina offers open plan environments



For information, to get a quote or to book a CPD workshop

Please call:

+44 (0)2392 454 405

or E-mail: info@coopersfire.com WWW.COOPERSFIRE.COM

© Coopers Fire Ltd. All content and products are copyright of Coopers Fire Ltd. Registered in England Number: 2010274. Multiple patents granted and pending.

Coopers Fire Ltd Ignis House, Houghton Avenue Waterlooville, Hampshire PO7 3DU. United Kingdom

Phone: +44 (0)2392 454 405 Email: info@coopersfire.com Web: www.coopersfire.com Coopers Fire Ltd has a policy of continuous product improvement.

As such we reserve the right to change design and specifications without prior notice.

Please check our website for the latest information.

MAR-042-FireMaster Concertina Egress-02-25-V1-A4

