

Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR-FA5013

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

SmokeStop[®] Active Smoke Barrier Overlapping or Single Barrel System (A1 Fabric)

Intended use: Smoke barrier for smoke control in construction works in industrial and commercial locations

Essential characteristics	Level or Class	Technical specification
Operational Reliability	Pass	EN 12101-1:2005/A1:2006, Clause 5.3
Response Delay	Pass	EN 12101-1:2005/A1:2006, Clause 5.4
Deployment Safety	Pass	EN 12101-1:2005/A1:2006, Clause 5.4
Fire Resistance - Smoke Leakage	Pass	EN 12101-1:2005/A1:2006, Clause 5.5.5
Fire Resistance - Mechanical Stability	DH120	EN 12101-1:2005/A1:2006, Clause 5.2
Fire Resistance - Integrity	DH120	EN 12101-1:2005/A1:2006, Clause 5.2

Certificate of Constancy of Performance

2812-CPR-FA5013

Placed on the Market under the Name of:

**Coopers Fire Ltd
Ignis House
Houghton Avenue
Waterlooville
Hampshire
PO7 3DU
United Kingdom**

and produced in the manufacturing plant

E/355

This is coded format, and the information is held by the Notified Body

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard:

EN 12101-1:2005/A1:2006

Under System 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **24/09/2020** and revised on **17/06/2023** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

CE Marking certificate valid to: **09/11/2025**

ERO Project Reference: **ERO 034621 P1799**



Paul Duggan
Certification Manager