# certifire

## CERTIFICATE OF APPROVAL No CF 5794

This is to certify that, in accordance with TS00 General Requirements for Certification of Fire Protection Products The undermentioned products of

### **COOPERS FIRE LTD**

#### Ignis House, Houghton Avenue, Waterlooville, Hampshire, England, PO7 3DU

Phone: 02392 454405

Have been assessed against the requirements of the Technical Schedule(s) denoted below and are approved for use subject to the conditions appended hereto:

CERTIFIED PRODUCT SmokeStop<sup>®</sup> Active Smoke Barrier Overlapping System (A1 Fabric)

### TECHNICAL SCHEDULE

TS 30 – Industrial Type Fire Resisting Doorsets

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan Certification Manager



Issued: Revised: Valid to: 29<sup>th</sup> October 2019 03<sup>rd</sup> September 2020 28<sup>th</sup> October 2024

Page 1 of 2



This certificate is the property of Warringtonfire Testing and Certification Limited Registered in England and Wales Registered Office: 10 Lower Grosvenor Place, London, United Kingdom, SW1W 0EN. Company Registration No: 11371436

# certifire

## CERTIFICATE No CF 5794 COOPERS FIRE LTD

- 1. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
- 2. This approval relates to the performance of active smoke barriers, manufactured by Coopers Fire Ltd. The barriers are certificated against the following performance requirements of EN 12101-1: 2006, at a maximum overall height (inc. headbox) of 4840mm:

Annex D - Temperature time (DH120 Classification). Annex C - Smoke permeability (leakage rate not exceeding 25 m<sup>3</sup> per hour per m<sup>2</sup>). Annex B - Reliability/Response/Durability (pass).

- The aforementioned barriers are also separately certificated against the essential requirements of Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR) under Certificate of Constancy of Performance referenced 1121-CPR-FA5013.
- 4. The product is CERTIFIRE approved on the basis of:
  - i) Initial type testing.
  - ii) An appraisal against TS30.
  - iii) Inspection and surveillance of factory production control
  - iv) Audit testing
- 5. The approval relates to on-going production. Product and/or its immediate packaging is identified with the manufacturers' name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.

Signed E/355

fal hagg-

Issued: 29<sup>th</sup> October 2019 Revised: 03<sup>rd</sup> September 2020 Valid to: 28<sup>th</sup> October 2024

Page 2 of 2