



coopers

SMOKE AND FIRE CURTAINS

**UK UK
CANI**

Declaration of Performance

SmokeStop A1 Smoke Barrier(s)

Unique identification code of the product-type:

SmokeStop (A1) Smoke Barrier(s); type ASB1/3

Intended use:

Smoke control in construction works in industrial and commercial locations

Name and address of the manufacturer:

Coopers Fire Limited
Ignis House, Houghton Avenue, Waterlooville,
Hants. PO7 3DU, UK

Notified body:

Name: Warringtonfire UK
Number: 1121
Activity: Issuance of new certificate
Certificate: 1121-CPR-FA7000

Declared performance

Essential characteristics	Performance	Harmonised technical specification
Operational reliability	Pass	EN 12101-1: 2005+A1:2006, clause 5.3
Response delay	Pass	EN 12101-1: 2005+A1:2006, clause 5.4
Deployment safety	Pass	EN 12101-1: 2005+A1:2006, clause 5.4
Resistance to fire:	Pass	EN 12101-1: 2005+A1:2006, clause 5.2
Smoke leakage	DH120	- 5.5
Mechanical stability	DH120	
Integrity	DH120	

David Cerquella

Managing Director
Date: 9th January 2023

CF-DOC-SSDH
CFL-CF-065
v02 January 2023

COOPERS FIRE LTD
IGNIS HOUSE, HOUGHTON AVENUE,
WATERLOOVILLE, HAMPSHIRE, UK. PO7 3DU
T: +44 (0)2392 454 405
WWW.COOPERSFIRE.COM

COMPANY REGISTRATION
REGISTERED IN ENGLAND NUMBER: 2010274
REGISTERED OFFICE:
IGNIS HOUSE, HOUGHTON AVENUE,
WATERLOOVILLE, HAMPSHIRE, UK. PO7 3DU

