



Declaration of Performance

FIREMASTER® HORIZONTAL SIMPLEX FIRE CURTAIN BARRIER(S)

Manufacturer	COOPERS FIRE LIMITED, Ignis House, Houghton Avenue, Waterlooville, Hampshire, PO7 3DU, United Kingdom
Product:	FireMaster® Horizontal Active Fire Curtain
Fire Resistance:	120 minutes Integrity
Test Standard:	BS EN 1634-1:2014 + A1:2018
Certificate Number:	CF 5795
Certified Body	WarringtonFire Testing and Certification Limited

Date of Issue: 4th May 2022

David Cerquella

Managing Director
Date: 4th May 2022

COOPERS FIRE LTD
IGNIS HOUSE, HOUGHTON AVENUE,
WATERLOOVILLE, HAMPSHIRE, UK. PO7 3DU
T: +44 (0)2392 454 405
WWW.COOPERSFIRE.COM

COMPANY REGISTRATION
REGISTERED IN ENGLAND NUMBER: 2010274
REGISTERED OFFICE:
IGNIS HOUSE, HOUGHTON AVENUE,
WATERLOOVILLE, HAMPSHIRE, UK. PO7 3DU

