



CERTIFICATE OF APPROVAL

No CF 5753

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

COOPERS FIRE LTD

Ignis House, Houghton Avenue, Waterlooville, Hampshire PO7 3DU
TEL: 02392 454405

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT

FireMaster® Active Fire Curtain

TECHNICAL SCHEDULE

TS 30 – Industrial Type Fire
Resisting Doorsets

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan
Certification Manager



Issued: 17th July 2019
Reissued: 31st July 2024
Valid to: 16th July 2029





CERTIFICATE No CF 5753

Coopers Fire Ltd

FireMaster® Active Fire Curtain

1. This approval relates to the use of FireMaster® Active Fire Curtains in providing a fire resistance performance of up to 240 minutes integrity performance, as defined in BS EN 1634-1: 2014. The scope of approval is summarised as follows:

Continuous Barrier / Single Roller

Integrity (mins)	Maximum height (mm)	Maximum Width (mm)
180	3125	7000
240	2500	7000

All dimensions quoted in the above tables are internally between guides and from underside of head box to floor level (i.e. visible fabric dimensions)

2. The product is CERTIFIRE approved on the basis of:
- i) Initial type testing.
 - ii) An appraisal against TS30.
 - iii) Inspection and surveillance of factory production control.
 - iv) Audit testing at a frequency defined within TS30.
3. The approval relates to on-going production. Product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.
4. The FireMaster® Active Fire Curtains are approved for installation into concrete, masonry or timber stud partitions having a fire performance no less than that required for the fire curtain. Typical installation details are provided in the datasheet. Furthermore the FireMaster® Active Fire Curtains are approved for installation into apertures formed by structural steel elements (conditions apply and must be met in full – see Data Sheet).
5. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.

Page 2 of 2

Issued:
Reissued:
Valid to:

17th July 2019
31st July 2024
16th July 2029