



SB3A-001

## **Declaration of Performance**

- Unique identification code of the product type:
   SmokeStop® Active Smoke Barrier Overlapping or Single Barrel System (A1 Fabric)
- 2. **Type:** Overlapping or Single Barrel System; Type ASB1/3
- 3. **Intended use:** Smoke barriers for smoke control in construction works in industrial and commercial locations
- Name and address of manufacturer: Coopers Fire Limited,
   Ignis House, Houghton Avenue, Waterlooville, Hampshire. PO7 3DU, UK
- System or systems of assessment and verification of constancy of performance of the construction product: System 1
- 6. Notified body:

Name: Element Materials Technology Rotterdam B.V. Notified Body I.D. Number: 2812

Activities performed under system 1: Determination of product type, initial inspection of the manufacturing plant and of FPC, the continuous surveillance, assessment and evaluation of the FPC and issued certificate of constancy of performance for the above product

Essential Characteristics	Performance	Harmonised Technical Specification
Operational reliability	Pass	EN 12101-1:2005 + A1:2006 Clause 5.3
Response delay	Pass	EN 12101-1:2005 + A1:2006 Clause 5.4
Deployment safety	Pass	EN 12101-1:2005 + A1:2006 Clause 5.4
Fire Resistance – Smoke leakage	Pass	EN 12101-1:2005 + A1:2006 Clause 5.5.5
Fire Resistance – Mechanical Stability	DH120	EN 12101-1:2005 + A1:2006 Clause 5.2
Fire Resistance—Integrity	DH120	EN 12101-1:2005 + A1:2006 Clause 5.2

8. The performance of the product identified above is in conformity with the set of declared performances in point 7. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

David Cerquella

() Junua

Managing Director



Date:

COMPANY REGISTRATION
REGISTERED IN ENGLAND NUMBER: 2010274
REGISTERED OFFICE:
IGNIS HOUSE, HOUGHTON AVENUE,
WATERLOOVILLE. HAMPSHIRE. UK. PO7 3DU

10 March 2023







