



Declaration of Performance

FIREMASTER® (OVERLAPPED) FIRE CURTAIN BARRIER(S)

Manufacturer	COOPERS FIRE LIMITED, Ignis House, Houghton Avenue, Waterlooville, Hampshire, PO7 3DU, United Kingdom
Product:	FireMaster® A1 Active Fire Curtain Barrier Assembly as an 'overlapped' construction using EFP™ A1 fabric
Fire Resistance:	120 minutes Integrity and 30 minutes Radiation performance to BS EN 1634-1:2014 (BS EN 1363-1:2016 & BS EN 1363-2:1999)
Classification:	E120 EW30 to BS EN 13501-2:2016+A1:2009
IFC Certification Number Product Standard:	IFCC1161 BS 8524-1:2013
Certification Notified Body	IFC CERTIFICATION LTD, 20 Park Street, Princes Risborough, Buckinghamshire, HP27 9AH, United Kingdom
Warrington Certification Number: Test Standard:	CF 5459 BS EN 1634-1:2014
Certification Notified Body:	WARRINGTONFIRE, Holmesfield Road, Warrington, Cheshire, WA1 2DS United Kingdom

Valid until: 31st August 2025

David Gerquella

Managing Director

Date: 09th February 2024

COOPERS FIRE LTD
IGNIS HOUSE, HOUGHTON AVENUE,
WATERLOOVILLE, HAMPSHIRE, UK. PO7 3DU
T: +44 (0)2392 454 405
WWW.COOPERSFIRE.COM

COMPANY REGISTRATION
REGISTERED IN ENGLAND NUMBER: 2010274
REGISTERED OFFICE:
IGNIS HOUSE, HOUGHTON AVENUE,
WATERLOOVILLE, HAMPSHIRE, UK. PO7 3DU

