



## Declaration of Performance

### Vii® FIRE i-ZONE FIRE CURTAIN BARRIER(S)

|                                    |                                                                                                                         |
|------------------------------------|-------------------------------------------------------------------------------------------------------------------------|
| <b>Manufacturer:</b>               | COOPERS FIRE LIMITED, Ignis House, Houghton Avenue, Waterlooville, Hampshire. PO7 3DU. United Kingdom                   |
| <b>Product:</b>                    | Vii®Fire i-Zone Active Fire Curtain Barrier Assembly as an 'single' construction using EFP™ 2/1000/DGI fabric           |
| <b>Product Standard:</b>           | BS 8524-1:2013                                                                                                          |
| <b>Fire Resistance:</b>            | 180 minutes integrity and 60 minutes Radiation performance to BS EN 1634-1:2014 (BS EN 1363-1:2016 & BS EN 1363-2:1999) |
| <b>Classification:</b>             | E180 EW60 to BS EN 13501-2:2007+A1:2009                                                                                 |
| <b>IFC Certification Number</b>    | IFCC1219                                                                                                                |
| <b>Certification Notified Body</b> | IFC CERTIFICATION LTD, 20 Park Street, Princes Risborough, Buckinghamshire, HP27 9AH, United Kingdom                    |

**Valid until:** 22<sup>nd</sup> February 2026

David Gerquella

Managing Director  
Date: 09<sup>th</sup> February 2024

COOPERS FIRE LTD  
IGNIS HOUSE, HOUGHTON AVENUE,  
WATERLOOVILLE, HAMPSHIRE, UK. PO7 3DU  
T: +44 (0)2392 454 405  
[WWW.COOPERSFIRE.COM](http://WWW.COOPERSFIRE.COM)

COMPANY REGISTRATION  
REGISTERED IN ENGLAND NUMBER: 2010274  
REGISTERED OFFICE:  
IGNIS HOUSE, HOUGHTON AVENUE,  
WATERLOOVILLE, HAMPSHIRE, UK. PO7 3DU



LEADING THE WAY IN FIRE PROTECTION