



LISTING INFORMATION OF

Coopers Fire Ltd. 20 Minute to 3 Hour Fire Rated FireMaster Concertina Fire Barrier

SPEC ID: 32891

Coopers Fire Ltd.
Ignis House
Houghton Avenue
Waterlooville, Hampshire PO7 3DU
United Kingdom

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

LISTING INFORMATION

Coopers Fire Ltd. 20 Minute to 3 Hour Fire Rated FireMaster Concertina Fire Barrier, FireMaster® Concertina™, for use in steel stud/gypsum or masonry wall applications.

Classified to UL 10D (3 Hour Rating) and to UL 10B, UL 10C, and NFPA 252 (20 Minute Without Hose Rating). Maximum Tested Size: 2.60m wide x 2.80m high, with a 90 degree corner projection (each leg being 1.77m wide). Oversize certificates are available for sizes larger than what was tested. The AHJ may approve "oversize" doors with no size limitation based on an oversized certificate/label that states the door supplied is constructed in accordance with the certified design except for the size.

Approved to UL 10D.

UL 10B, UL 10C, and NFPA 252 standards apply to 20 Minute Fire Endurance ratings without hose stream only. Please note that acceptance of the UL 10B, UL10C, and NFPA 252 ratings for the fire curtain product noted above is ultimately at the discretion of the Authority Having Jurisdiction.

Attribute	Value
Criteria	NFPA 252 (2008)
Criteria	UL 10(c) (2009)
Criteria	UL 10(b) (2009)
Criteria	UL 10(d) (2009)
Criteria	NFPA 252 (2012)
Criteria	UL 10(d) (2014)
Criteria	UL 10(c) (2016)
Criteria	UL 10(b) (R2015)
CSI Code	08 30 00 Specialty Doors and Frames
Fire Resistance	20 Min w/out Hose Negative Pressure
Fire Resistance	20 Min w/out Hose Positive Pressure
Fire Resistance	3 Hour Positive Pressure
Intertek Services	Certification
Listed or Inspected	LISTED
Listing Section	DOORS
Report Number	G101095457
Spec ID	32891
Verification Test Type	ASTM E1252
Verification Testing	YES
Verification Testing Lab	MID - Middleton, WI