



## Declaration of Performance

### FIREMASTER® SUPERPLUS FIRE CURTAIN BARRIER(S)

<b>Manufacturer:</b>	COOPERS FIRE LIMITED, Ignis House, Houghton Avenue, Waterlooville, Hampshire. PO7 3DU. United Kingdom
<b>Product:</b>	FireMaster® SuperPlus Active Fire Curtain Barrier Assembly as an 'overlapped' construction using EFP™ 4/1000 fabric
<b>Product Standard:</b>	BS EN 1634-1:2000 & BS EN 1363-1:1999
<b>Fire Performance:</b>	120 minutes Integrity (E 120) and 120 minutes Insulation (EI 120) performance (when used in conjunction with an external sprinkler) to BS EN 1634-1:2000 (BS EN 1363-1:1999)
<b>Classification Conclusion Report:</b>	IFC 090814/04/Rev3
<b>Reliability Test:</b>	CHILT/P/08077/A BS EN 12605:2000 - 700 Cycles
<b>Certification Notified Body</b>	IFC CERTIFICATION LTD, 20 Park Street, Princes Risborough, Buckinghamshire, HP27 9AH, United Kingdom

**Date of Issue:** 11<sup>th</sup> May 2019  
**Valid until:** 10<sup>th</sup> January 2025

David Gerquella

Managing Director  
Date: 11<sup>th</sup> January 2021

Version 04-Nov23

COOPERS FIRE LTD  
IGNIS HOUSE, HOUGHTON AVENUE,  
WATERLOOVILLE, HAMPSHIRE, UK. PO7 3DU  
T: +44 (0)2392 454 405  
[WWW.COOPERSFIRE.COM](http://WWW.COOPERSFIRE.COM)

COMPANY REGISTRATION  
REGISTERED IN ENGLAND NUMBER: 2010274  
REGISTERED OFFICE:  
IGNIS HOUSE, HOUGHTON AVENUE,  
WATERLOOVILLE, HAMPSHIRE, UK. PO7 3DU

